BEGA 50 733

Ceiling and wall luminaire for indoor use

Project · Reference number

Date

Product data sheet

Application

Ceiling and wall luminaire with emergency lighting according to DIN EN 60598-2-22 and DIN VDE 0108-100 for safety lighting facilities. With integral accumulator for 3 hours emergency operation in case of mains failure.

Product description

Metal housing, finish white enamel Hand-blown opal glass, satin matt, with bayonet closure 2 mounting holes ø 5.5 mm Distance apart 230 mm 2 cable entries for through-wiring for mains cable up to Ø 10.5 mm max. 4 × 1.5 Connection terminal 2.5 Earth conductor connection Emergency lighting module with self test facility 220-240 V \sim 50/60 Hz NiMH accumulator for 3 hours emergency operation at 5°...+25 °C LED power supply unit 220-240 V \sim 50/60 Hz Safety class I Impact strength IK03 Protection against mechanical impacts < 0.35 joule C € – Conformity mark Weight: 2.9 kg

Lamp

50733K3

Module designation	LED-0511/930
Colour temperature	3000 K
Colour rendering index	CRI > 90
Module luminous flux	2110 lm
Luminaire luminous flux	1437 lm
Luminaire luminous efficiency	71,8 lm/W

50 733 K2

Module designation	LED-0511/927
Colour temperature	2700 K
Colour rendering index	CRI > 90
Module luminous flux	2095 lm
Luminaire luminous flux	1425 lm
Luminaire luminous efficiency	71,2 lm/W

50733K4

00700114	
Module designation	LED-0511/940
Colour temperature	4000 K
Colour rendering index	CRI > 90
Module luminous flux	2185 lm
Luminaire luminous flux	1488 lm
Luminaire luminous efficiency	74,4 lm/W

Emergency operation 3 h


LED 4 W

Luminaire luminous flux 319 lm

Light technique

Luminaire data for the light planning program DIALux for outdoor lighting, street lighting and indoor lighting as well as luminaire data in EULUMDAT- and IES-format you will find on the BEGA web page www.bega.com.





Service life of the LED

max. ambient temperature t_a = 25 °C – at 178,000 h: L70 B50

Testing

This luminaire has a self-test function to comply with statutory requirements. This self-test is performed weekly (function test) and annually (operating period test).

The function test is performed once a week for 5 seconds and is controlled by the microprocessor. The initiation including date and time of this test is performed when the luminaire is commissioned.

A complete operating period test is performed annually to check the battery power.

Article No. 50733

LED colour temperature optionally 2700 K, 3000 K or 4000 K

2700 K – Article number + **K2** 3000 K – Article number + **K3** 4000 K – Article number + **K4**

If the article number is followed by a **P**, we can also supply these luminaires in impact-resistant synthetic material.

$\textbf{Accessory} \cdot \textbf{Trim rings}$

For this luminaire metal cover rings in 3 enamel surfaces are optional available.

Trim rings are accessories and must be ordered separately.

ItemPart. NoFinish enamel white13 004Finish enamel palladium13 005Finish enamel glossy silver13 006