Design iGuzzini

iGuzzini

Last information update: May 2018

### 600x600 - Neutral White - general light

#### Product code P015


## Technical description

Recessed direct emission luminaire designed to use Neutral White colour 4000K LEDs and be installed in 600x600 modular false ceilings or in plasterboard using a frame to be ordered as an accessory. The optical assembly is made of a thermoplastic material with a satin methacrylate diffuser screen for general light emission. Product complete with electronic components.

### Installation

Dimension (mm) 600x600

Recessed for installation in 600x600 modular false ceilings or in plasterboard using a frame to be ordered as an accessory.



Colour

White (01)



Weight (Kg) 2.56

### Mounting

ceiling recessed|wall surface

# Wiring

product complete with electronic components



### Product configuration: P015

### Product characteristics


Total lighting output [Lm]: 3519.6 Total power [W]: 31.1 Luminous efficacy [Lm/W]: 113.2 Life Time: 50,000h - L80 - B10 (Ta 25°C)

# Optical assembly Characteristics Type 1


Light Output Ratio (L.O.R.) [%]: 80 Lamp code: LED ZVEI Code: LED Nominal power [W]: 27 Nominal luminous [Lm]: 4400 Lamp maximum intensity [cd]: / Beam angle [°]: / Total luminous flux at or above an angle of 90° [Lm]: 0 Emergency luminous flux [Lm]: / Voltage [V]: - Number of optical assemblies: 1

Number of lamps for optical assembly: 1 Socket: / Ballast losses [W]: 4.1 Colour temperature [K]: 4000 CRI: 80 Wavelength [Nm]: / MacAdam Step: 3

Complies with EN60598-1 and pertinent regulations



R	77	75	73	71	55	53	33	00	DRR
K0.8	52	44	38	33	42	37	36	31	39
1.0	58	50	44	39	48	43	42	37	46
1.5	66	59	54	50	58	53	52	47	59
2.0	71	65	61	57	64	60	59	54	68
2.5	74	69	66	62	68	64	63	59	73
3.0	76	72	69	66	70	68	66	62	78
4.0	79	75	73	70	74	71	70	66	83
5.0	80	77	75	73	76	74	72	69	86



DC A	G	1.15	2000	1000	500		<-300		
В		1.50		2000	1000	750	500	<=300	
C		1.85			2000		1000	500	<-300
35°			/ /						
									- 6
75°			$\leftarrow$						4
75°			$\leftarrow$						- '
			$\leq$						
65°				$\sum$	A				
75° 85° 55°					<u> </u>				
5°		103					8 10		

UGR diagram

D:fla											
Riflect.:		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
ceil/cav walls work pl. Room dim		0.50	0.30	0.50	0.30	0.30	0.50		0.50	0.30	0.30
		0.20	0.20	0.20	0.20	0.30	0.20	0.30	0.20	0.30	0.30
		0.20	0.20	viewed	0.20	0.20	0.20	0.20	viewed	0.20	0.20
x y				rosswise					endwise		
^	y			103344130					CHUWISC		
2H	2H	17.5	18.7	17.8	19.0	19.3	17.5	18.7	17.8	19.0	19.3
	ЗH	19.1	20.2	19.4	20.5	20.8	18.0	19.1	18.3	19.4	19.7
	4H	19.7	20.8	20.1	21.1	21.4	18.2	19.2	18.5	19.5	19.9
	6H	20.2	21.2	20.6	21.5	21.9	18.3	19.2	18.6	19.6	19.9
	BH	20.4	21.3	20.8	21.6	22.0	18.3	19.2	18.7	19.5	19.9
	12H	20.5	21.4	20.9	21.7	22.1	18.3	<b>1</b> 9.1	18.6	19.5	19.9
4H	2H	18.2	19.2	18.5	19.5	19.9	19.7	20.8	20.1	21.1	21.4
	ЗH	20.0	20.9	20.4	21.2	21.6	20.4	21.3	20.8	21.6	22.0
	4H	20.7	21.5	21.1	21.9	22.3	20.7	21.5	21.1	21.9	22.3
	6H	21.3	22.0	21.8	22.4	22.9	20.9	21.6	21.4	22.0	22.5
	8H	21.5	22.2	22.0	22.6	23.0	21.0	21.6	21.5	22.1	22.5
	12H	21.7	22.3	22.1	22.7	23.2	21.0	21.6	21.5	22.0	22.5
вн	4H	21.0	21.6	21.5	22.1	22.5	21.5	22.2	22.0	22.6	23.0
	6H	21.8	22.3	22.2	22.8	23.2	21.9	22.4	22.4	22.9	23.4
	HS	22.1	22.5	22.5	23.0	23.5	22.1	22.5	22.5	23.0	23.5
	12H	22.3	22.7	22.8	23.2	23.7	22.2	22.6	22.7	23.0	23.6
12H	4H	21.0	21.6	21.5	22.0	22.5	21.7	22.3	22.1	22.7	23.2
	6H	21.8	22.3	22.3	22.8	23.3	22.1	22.5	22.6	23.0	23.5
	8H	22.2	22.6	22.7	23.0	23.6	22.3	22.7	22.8	23.2	23.7
Varia	tions wi	th the ob	oserverp	osition a	at spacin	g:					
S =	1.0H		CONTRACTOR OF T	.1 / -0.	Contraction of the second			C	0.1 / -0.	1	
	1.5H			2 / -0.					.2 / -0.3		
	2.0H	0.4 / -0.5						0	.4 / -0.	5	