Design iGuzzini

iGuzzini


Last information update: May 2018

### Frame Adjustable Recessed Luminaire - Warm White LED - Wide Flood beam - ON-OFF

#### Product code P730

#### Technical description

Recessed luminaire with adjustable optic for warm white LED 2700K with high colour rendering index. Passive cooling system. Adjustable body can be rotated within the recess to ensure precise but comfortable lighting and considerably reduced direct glare. 355° internal rotation and max 30° oscillation with continuous friction. Fixed recess structure in die-cast aluminium with perimeter stop frame. The recessed luminaire includes a radiant aluminium element, a steel junction for the optical assembly and a thermoplastic rotation ring. Metallised thermoplastic reflector with high definition optic and wide flood beam aperture. External thermoplastic anti-glare screen. Transparent protection glass for LED light source. Supplied with electronic power supply unit connected to the luminaire.



## Installation

Recessed with torsional steel springs - 1 mm minimum thickness of false ceiling - recess opening 76 x 76 mm.

#### Dimension (mm) 86x86x111

Colour

White (01) | Black/Black (43) | Black/White (47) | Grey/Black (74)

Weight (Kg)

# 0.53

## Mounting

wall recessed ceiling recessed

## Wiring

Quick-fit power supply connection to terminal block.

#### Notes

Vast range of technical and decorative accessories available; option to install 2 accessories at the same time.



#### Product configuration: P730.01

# Product characteristics Total lighting output [Lm]: 689.3 Total luminous flux at or above an angle of 90° [Lm]: 0 Total power [W]: 11.6 Emergency luminous flux [Lm]: / Luminous efficacy [Lm/W]: 59.4 Voltage [V]: 230 Life Time: 50,000h - L80 - B10 (Ta 25°C) Number of optical assemblies: 1 Optical assembly Characteristics Type 1 Unit of the second second

Light Output Ratio (L.O.R.) [%]: 69 Lamp code: LED ZVEI Code: LED Nominal power [W]: 9.1 Nominal luminous [Lm]: 1000 Lamp maximum intensity [cd]: / Beam angle [°]: 50° Number of lamps for optical assembly: 1 Socket: / Ballast losses [W]: 2.5 Colour temperature [K]: 2700 CRI: 90 Wavelength [Nm]: / MacAdam Step: 3

Complies with EN60598-1 and pertinent regulations

Polar

Imax=1048 cd	CIE	Lux			
90° 180° 90°	nL 0.69 100-100-100-100-69 UGR <10-<10	h	d	Em	Emax
	DIN A.61	1	0.9	880	1048
	0.69A+0.00T F"1=996	2	1.9	220	262
	F"1+F"2=999 F"1+F"2+F"3=1000 CIBSE	3	2.8	98	116
α=50°	LG3 L<200 cd/m² at 65° BZ1	4	3.7	55	66

## Utilisation factors

R	77	75	73	71	55	53	33	00	DRR
K0.8	62	59	57	55	58	56	56	54	78
1.0	65	62	60	58	61	60	59	57	83
1.5	68	66	64	63	65	64	63	61	89
2.0	70	69	67	66	68	67	66	64	93
2.5	72	70	69	69	69	69	68	66	96
3.0	72	72	71	70	70	70	69	67	98
4.0	73	73	72	72	71	71	70	68	99
5.0	74	73	73	73	72	72	71	69	100

## Luminance curve limit

A G	1.15	2000	1000	500		<-300		
в	1.50		2000	1000	750	500	<=300	
C	1.85			2000		1000	500	<=300
					_ / _			
								8
								4
-								
								- 2
								4
	_							a
						$\mathbf{N}$		_ h
		3 4 5	6 8 1	0 <sup>3</sup>	2 3	4 5 6	8 10 <sup>4</sup>	cd/m <sup>2</sup>
2						4 5 6		
	BC	B 1.50 C 1.85	B 1.50 C 1.85	B 1.50 2000 C 1.85	B 1.50 2000 1000 C 1.85 2000	B   1.50   2000   1000   750     C   1.05   2000   1000	B   1.50   2000   1000   750   500     C   1.85   2000   1000	B   1.50   2000   1000   750   500   <-300     C   1.85   2000   1000   500 </td

UGR diagram

Difle											
Riflect.:		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
ceil/cav walls work pl. Room dim x y		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
		0.20	0.20	viewed		0.20	0.20	0.20	viewed	0.20	0.20
		crosswise						endwise			
	,						-				
2H	2H	10.0	10.6	10.3	10.8	11.0	10.0	10.6	10.3	10.8	11.0
	3H	9.9	10.4	10.2	10.7	10.9	9.9	10.4	10.2	10.7	10.9
	4H	9.8	10.3	10.2	10.6	10.9	9.8	10.3	10.2	10.6	10.9
	6H	9.8	10.2	10.1	10.5	10.8	9.8	10.2	10.1	10.5	10.8
	8H	9.7	10.1	10.1	10.5	10.8	9.7	10.1	10.1	10.5	10.8
	12H	9.7	10.1	10.1	10.4	10.8	9.7	10.1	10.1	10.4	10.8
4H	2H	9.8	10.3	10.2	10.6	10.9	9.8	10.3	10.2	10.6	10.9
	ЗH	9.7	10.1	10.1	10.4	10.8	9.7	10.1	10.1	10.4	10.8
	4H	9.6	9.9	10.0	10.3	10.7	9.6	9.9	10.0	10.3	10.7
	6H	9.5	9.8	9.9	10.2	10.6	9.5	9.8	9.9	10.2	10.0
	BH	9.5	9.7	9.9	10.2	10.6	9.5	9.7	9.9	10.2	10.6
	12H	9.4	9.7	9.9	10.1	10.6	9.4	9.7	9.9	10.1	10.5
вн	4H	9.5	9.7	9.9	10.2	10.6	9.5	9.7	9.9	10.2	10.6
	6H	9.4	9.6	9.8	10.0	10.5	9.4	9.6	9.8	10.0	10.5
	HS	9.3	9.5	9.8	10.0	10.5	9.3	9.5	9.8	10.0	10.5
	12H	9.3	9.4	9.8	9.9	10.4	9.3	9.4	9.8	9.9	10.4
12H	4H	9.4	9.7	9.9	10.1	10.5	9.4	9.7	9.9	10.1	10.6
	6H	9.3	9.5	9.8	10.0	10.5	9.3	9.5	9.8	10.0	10.5
	8H	9.3	9.4	9.8	9.9	10.4	9.3	9.4	9.8	9.9	10.4
Varia	tions wi	th the ot	oserver p	osition	at spacin	ig:					
S =	1.0H		5 / -18	.7	6.5 / -18.7						
	1.5H		3 / -19	2	9.3 / -19.2						
	2.0H		.3 / -19	9.4	11.3 / -19.4						