Design Iosa Ghini

iGuzzini

Last information update: June 2018



recessed luminaire \emptyset 137 - warm white passive dissipation LED - integrated DALI control gear - wide flood

Product code

Q194

Technical description

recessed adjustable removable luminaire for LED lamp with passive heat dissipation system. Structure with die-cast aluminium frame and main body; shaped surface with high level radiant effect for effectively reducing the temperature and keeping the long-term LED lamp performance unchanged. Steel rotation hinge, chrome-plated aluminium body closing ring. Reflector with high efficiency super-pure aluminium optic - wide flood beam angle. Body adjusted using manually operated device: internal 30° - external 75° - rotation about axis 355°. Supplied with DALI dimmable control gear connected to the luminaire. Warm white high efficiency LED.



ø 137



Installation

recessed using steel springs in false ceilings with thicknesses starting at 1 mm; preparation hole Ø 125

Dimension (mm)

Ø137x91

Colour

White/Aluminium (39) | Grey/Aluminium (78)

Weight (Kg)

1.02

Mounting

ceiling recessed

Wiring

on control gear box with quick-coupling connections

Complies with EN60598-1 and pertinent regulations

















Product configuration: Q194

Product characteristics

Total lighting output [Lm]: 2338 Total power [W]: 24.6 Luminous efficacy [Lm/W]: 95

Life Time: > 50,000h - L80 - B10 (Ta 25°C)

Total luminous flux at or above an angle of 90 $^{\circ}$ [Lm]: 0

Emergency luminous flux [Lm]: / Voltage [V]: -

Number of optical assemblies: 1

Optical assembly Characteristics Type 1

Light Output Ratio (L.O.R.) [%]: 78

Lamp code: LED ZVEI Code: LED Nominal power [W]: 22 Nominal luminous [Lm]: 3000 Lamp maximum intensity [cd]: / Beam angle [°]: 54° Number of lamps for optical assembly: 1

Socket: /

Ballast losses [W]: 2.6 Colour temperature [K]: 3000

CRI: 80

Wavelength [Nm]: / MacAdam Step: 2

Polar

Imax=3107 cd	CIE	Lux			
90° 180° 90°	nL 0.78 97-100-100-100-78	h	d	Em	Emax
	UGR 19.9-19.9 DIN A.61	2	2	600	773
K XIX X	UTE 0.78A+0.00T F"1=965	4	4.1	150	193
3000	F"1+F"2=997 F"1+F"2+F"3=1000	6	6.1	67	86
0° α=54°		8	8.2	38	48

Utilisation factors

R	77	75	73	71	55	53	33	00	DRR
K0.8	69	65	63	60	65	62	62	59	76
1.0	72	69	66	65	68	66	66	63	81
1.5	76	74	72	70	73	71	70	68	87
2.0	79	77	75	74	76	75	74	71	92
2.5	80	79	78	77	78	77	76	74	95
3.0	81	80	80	79	79	78	77	75	97
4.0	83	82	81	81	80	80	79	77	98
5.0	83	82	82	82	81	81	79	78	99

Luminance curve limit

DC A	G 1.15	2000	1000	500		<=300		
В	1.50		2000	1000	750	500	<=300	
С	1.85			2000		1000	500	<=300
85°					11/11			3 8
75°				10				- 4
65°								
45° 10²	2	3 4	5 6 8	10 ³	2 3	4 5 6	8 104	cd/m²
C0-180		3 4	5 6 8	10-	C90-270	4 5 6	8 10	ca/m-

Corre	ected U(R value	at 3000) Im bar	e lamp li	ım inous	flux)					
Rifled	et.:											
ceil/cav		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30	
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30	
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	
Room dim		viewed					viewed					
х у		crosswise						endwise				
2H	2H	20.5	21.1	20.8	21.3	21.6	20.5	21.1	20.8	21.3	21.	
	ЗН	20.3	20.9	20.7	21.2	21.5	20.3	20.9	20.7	21.2	21.	
	4H	20.3	8.02	20.6	21.1	21.4	20.3	20.8	20.6	21.1	21.	
	бН	20.2	20.7	20.5	21.0	21.3	20.2	20.7	20.5	21.0	21.	
	H8	20.2	20.6	20.5	20.9	21.3	20.2	20.6	20.5	20.9	21.	
	12H	20.1	20.6	20.5	20.9	21.3	20.1	20.6	20.5	20.9	21.	
4H	2H	20.3	20.8	20.6	21.1	21.4	20.3	20.8	20.6	21.1	21.	
	ЗН	20.1	20.6	20.5	20.9	21.3	20.1	20.6	20.5	20.9	21.	
	4H	20.0	20.4	20.4	20.8	21.2	20.0	20.4	20.4	20.8	21.	
	бН	20.0	20.3	20.4	20.7	21.1	20.0	20.3	20.4	20.7	21.	
	HS	19.9	20.2	20.4	20.6	21.1	19.9	20.2	20.4	20.6	21.	
	12H	19.9	20.1	20.3	20.6	21.0	19.9	20.1	20.3	20.6	21.	
нв	4H	19.9	20.2	20.4	20.6	21.1	19.9	20.2	20.4	20.6	21.	
	6H	19.8	20.1	20.3	20.5	21.0	19.8	20.1	20.3	20.5	21.	
	HS	19.8	20.0	20.3	20.5	21.0	19.8	20.0	20.3	20.5	21.	
	12H	19.7	19.9	20.2	20.4	20.9	19.7	19.9	20.2	20.4	20.9	
12H	4H	19.9	20.1	20.3	20.6	21.0	19.9	20.1	20.3	20.6	21.	
	бН	19.8	20.0	20.3	20.5	21.0	19.8	20.0	20.3	20.5	21.0	
	HS	19.7	19.9	20.2	20.4	20.9	19.7	19.9	20.2	20.4	20.	
		th the ob	A CADE COST		Service Company	ıg:						
S =	1.0H		1 / -13		5.1 / -13.5							
	1.5H 2.0H	7.9 / -1 4.7					7.9 / -14.7					