Design iGuzzini / Arup

iGuzzini

Last information update: May 2018

round small body spotlight - wide flood



# Product code

Q289

#### Technical description

Indoor adjustable spotlight with adapter for installation on a three-phase/DALI track. Device made of die-cast aluminium and a front part made of a thermoplastic material. Spotlight double adjustability allows a 360° rotation about the vertical axis and 90° tilting relative to the horizontal plane. Optical assembly consisting of Neutral White tone 4000K LEDs with OPTIBEAM LENS technology and a wide flood light beam. Dimmable DALI driver built-in to box with a semi-hidden system on track. Option of installing a range of flat accessories including an OPTIBEAM REFRACTOR for varying light distribution, an elliptical distribution refractor, a louver, a soft lens and an outdoor accessory like an asymmetric visor for eliminating stray light dispersion on the ceiling.



On a three-phase/DALI electrified track

### Dimension (mm)

Ø126x164

#### Colour

Black (04) | Black/White (47)

#### Weight (Kg)

0.99

## Mounting

dali track|three circuit track

#### Wiring

Product complete with DALI dimmable components, housed in a semi-hidden box on the track.

Complies with EN60598-1 and pertinent regulations




















# **Product characteristics**

Total lighting output [Lm]: 1990.1 Total power [W]: 21.3

Luminous efficacy [Lm/W]: 93.4

Life Time: > 50,000h - L80 - B10 (Ta 25°C)

Total luminous flux at or above an angle of 90° [Lm]: 0

Emergency luminous flux [Lm]: /

Voltage [V]: -

Number of optical assemblies: 1

# Optical assembly Characteristics Type 1

Light Output Ratio (L.O.R.) [%]: 83

Lamp code: LED ZVEI Code: LED Nominal power [W]: 18 Nominal luminous [Lm]: 2400 Lamp maximum intensity [cd]: / Beam angle [°]: 46° Number of lamps for optical assembly: 1

Socket: /

Ballast losses [W]: 3.3 Colour temperature [K]: 4000

CRI: 80

Wavelength [Nm]: / MacAdam Step: 2

# Polar

Imax=2999 cd	CIE	Lux			
90°	nL 0.83 91-98-100-100-83	h	d	Em	Emax
	UGR 21.5-21.4 DIN A.61 UTE	2	1.7	579	750
	0.83A+0.00T F"1=907	4	3.4	145	187
2000	F"1+F"2=977 F"1+F"2+F"3=996 CIBSE	6	5.1	64	83
α=46°	BZ1	8	6.8	36	47



### **Utilisation factors**

R	77	75	73	71	55	53	33	00	DRR
K0.8	71	67	63	61	66	63	62	59	72
1.0	75	71	68	65	70	67	67	64	77
1.5	80	77	74	72	76	73	73	70	84
2.0	83	80	78	77	79	77	77	74	89
2.5	85	83	81	80	82	80	79	77	92
3.0	86	84	83	82	83	82	81	79	95
4.0	87	86	85	84	85	84	83	80	97
5.0	88	87	86	86	85	85	83	81	98

### Luminance curve limit

2C	A G	1.15	2000	1000	500		<=300		
	В	1.50		2000	1000	750	500	<=300	
	С	1.85			2000		1000	500	<=300
5°			(						
5°									-
5° 6	8	10 <sup>3</sup>		2	3 4	5 6	8 10	,	cd/m²
	-180					C90-270 -			

Riflect ceil/ca walls work Room x 2H	pl.	0.70 0.50 0.20 20.7 21.0 21.1 21.2 21.2 21.2	0.70 0.30 0.20 21.4 21.6 21.7 21.7 21.7	0.50 0.50 0.20 viewed crosswise 21.0 21.3 21.5	21.6 21.9	0.30 0.30 0.20	0.70 0.50 0.20	0.70 0.30 0.20	0.50 0.50 0.20 viewed endwise	0.50 0.30 0.20	0.30 0.30 0.20
walls work Room x 2H	pl. o dim y 2H 3H 4H 6H 8H	20.7 21.0 21.1 21.2 21.2	0.30 0.20 21.4 21.6 21.7 21.7	0.50 0.20 viewed crosswise 21.0 21.3 21.5	0.30 0.20 e 21.6 21.9	0.30 0.20	0.50 0.20	0.30 0.20	0.50 0.20 viewed endwise	0.30 0.20	0.30
work Room x 2H	pl. y  2H  3H  4H  6H  8H	20.7 21.0 21.1 21.2 21.2	21.4 21.6 21.7 21.7	0.20 viewed crosswise 21.0 21.3 21.5	0.20 e 21.6 21.9	21.9	20.7	0.20	0.20 viewed endwise	0.20	0.20
Room x 2H	2H 3H 4H 6H 8H 12H	20.7 21.0 21.1 21.2 21.2	21.4 21.6 21.7 21.7	21.0 21.3 21.5	e 21.6 21.9	21.9	20.7		viewed endwise		2000
х 2Н	2H 3H 4H 6H 8H 12H	21.0 21.1 21.2 21.2	21.4 21.6 21.7 21.7	21.0 21.3 21.5	21.6 21.9		2000	21.4	endwise		21.
2H	2H 3H 4H 6H 8H 12H	21.0 21.1 21.2 21.2	21.4 21.6 21.7 21.7	21.0 21.3 21.5	21.6 21.9		2000	21.4			21.
Serve II	3H 4H 6H 8H 12H	21.0 21.1 21.2 21.2	21.6 21.7 21.7	21.3 21.5	21.9		2000	21.4	21.0	21.6	21.
4H	4H 6H 8H 12H	21.1 21.2 21.2	21.7 21.7	21.5		22.2	(2) 14 h 5 h				
4H	6H 8H 12H	21.2 21.2	21.7			22.2	20.8	21.4	21.1	21.6	21.
4H	8H 12H	21.2			22.0	22.3	20.8	21.3	21.1	21.6	21.
4H	<b>1</b> 2H		217	21.5	22.0	22.3	20.7	21.2	21.1	21.6	21.
4H	170000	21.2	41.7	21.5	22.0	22.3	20.7	21.2	21.1	21.5	21.
4H	ЭH	CONTRACTOR OF THE PARTY OF THE	21.6	21.5	22.0	22.3	20.7	21.1	21.0	21.5	21.
	211	20.8	21.3	21.1	21.6	21.9	21.1	21.7	21.5	22.0	22.
	3H	21.2	21.6	21.6	22.0	22.3	21.3	21.8	21.7	22.1	22.
	4H	21.3	21.8	21.7	22.1	22.5	21.3	21.8	21.7	22.1	22.
	6H	21.5	21.8	21.9	22.2	22.6	21.4	21.7	21.8	22.1	22.
	8H	21.5	21.8	21.9	22.2	22.7	21.4	21.7	21.8	22.1	22.
	12H	21.5	21.8	21.9	22.2	22.7	21.3	21.6	21.8	22.1	22.
нв	4H	21.4	21.7	21.8	22.1	22.5	21.5	21.8	21.9	22.2	22.
	6H	21.5	21.8	22.0	22.3	22.7	21.6	21.8	22.0	22.3	22.
	8H	21.6	21.8	22.1	22.3	22.8	21.6	21.8	22.1	22.3	22.
	12H	21.6	21.8	22.1	22.3	22.8	21.6	21.8	22.1	22.3	22.
12H	4H	21.3	21.6	21.8	22.1	22.5	21.5	21.8	21.9	22.2	22.
	бН	21.5	21.7	22.0	22.2	22.7	21.5	21.8	22.0	22.3	22.
	H8	21.6	21.8	22.1	22.3	22.8	21.6	21.8	22.1	22.3	22.
Variat	tions wi	th the ob	oserverp	osition a	at spacin	ıg:					
5 =	1.0H			.3 / -1				2	2.3 / -1.9	9	
	1.5H		4	.4 / -2	.6		4	4.4 / -2.	δ		